


Sustainable Retrofitting


ROB WARNER




Energy Use in Commercial Buildings, 2003



Source: Energy Information Administration, *Annual Energy Review 2009*







Source: U.S. Energy Information Administration, *2003 Commercial Building Energy Consumption Survey, Table E1A* (September 2008).





Retrofitting Proposals

1. BAU
2. Exterior Storm
3. + Low-e Coating
4. Double paned
5. + Argon, low-e




ANNUAL COSTS	Natural Gas	Savings
Baseline Design Case	\$ 6,061	-
Exterior Wall Insulation	\$ 4,353	\$ 1,708
Improved Window Glass	\$ 2,278	\$ 3,783
Increased HVAC Efficiency	\$ 2,021	\$ 4,040


Loggers

Location		Model	Sensors	Range
1st floor	Core	HOBO U12-012	Temperature/Relative Humidity/Light	-4° to 158°F, 5% to 95% RH, 1 to 3k lumens/fts
	West	HOBO U10-003	Temperature/Relative Humidity	-4° to 158°F, 25% to 95% RH
2nd floor	East	HOBO U10-003	Temperature/Relative Humidity	-4° to 158°F, 25% to 95% RH
	Core	HOBO U12-012	Temperature/Relative Humidity/Light	-4° to 158°F, 5% to 95% RH, 1 to 3k lumens/fts
	West	HOBO U10-003	Temperature/Relative Humidity	-4° to 158°F, 25% to 95% RH
3rd Floor	East	HOBO U10-003	Temperature/Relative Humidity	-4° to 158°F, 25% to 95% RH
	Core	HOBO U12-012	Temperature/Relative Humidity/Light	-4° to 158°F, 5% to 95% RH, 1 to 3k lumens/fts
	West	HOBO U10-003	Temperature/Relative Humidity	-4° to 158°F, 25% to 95% RH
Roof	Core	HOBO Pro v2 - U23-001	Temperature/Relative Humidity	-40° to 158°F, 0-100% RH
	West	HOBO Pendant 8bit - UA-002-08	Temperature/Light	-4° to 158°F ,0 to 30k lumens/ft2
North Façade		HOBO Pro v2 - U23-001	Temperature/Relative Humidity	-40° to 158°F, 0-100% RH
South Façade		HOBO Pendant 8bit - UA-002-08	Temperature/Light	-4° to 158°F, 0 to 320k lux











Percent within Comfort Zone


- Temperature: 35.7%
- Relative Humidity
 - Summer: 62.2%
 - Annual: 83.0%








- Temperature: 35.6%
- Relative Humidity
 - Summer: 49.9%
 - Annual: 77.2%




- Temperature: 40.6%
- Relative Humidity
 - Summer: 11.4%
 - Annual: 58.9%









◆ 1st fl. Core
 ■ 2nd fl. Core
 ▲ 3rd fl. Core




◆ 1st fl. Core
 ■ 2nd fl. Core
 ▲ 3rd fl. Core



◆ 1st fl. Core
 ■ 2nd fl. Core
 ▲ 3rd fl. Core



◆ 1st fl. Core
 ■ 2nd fl. Core
 ▲ 3rd fl. Core



Solar Gain		
Solar Radiation (annual avg.)	3.1	kWh/m ² /day
Area of the South-facing windows	110.00	m ²
Solar gain = insolation x glazing area	124,461.83	kwh/yr
	424,701.11	kBtu/yr
x SHGC .86	365,242.95	kBtu/yr
Heat-loss of windows	610,443.38	kBtu/yr
Gain w/ double-paned addition	146,097.18	kBtu/yr
Accompanying heat loss	138,875.75	kBtu/yr



Thermal Comfort/IAQ vs. Energy Performance

- Air Quality
- Moisture relief
- Occupant comfort





- Tighter envelope
- Window performance



Solution: ERV

- Moisture retention/regulation
- Disperse coolth
- Reduce energy costs



RenewAir® Energy Recovery Ventilation *Simplicity - Reliability - Performance*

LOG OUT PROJECTS QUICKCALCS WEATHER DATA CHANGE PASSWORD

Project: [30 burnside](#) > Unit: ERV-1

Schedule Ventilation Annual Savings Images Reference Materials

	Heating		Cooling	
Number of months system on most days:	<input type="text" value="7"/>		<input type="text" value="5"/>	
Operation Hours per Week:	<input type="text" value="112"/>		<input type="text" value="112"/>	
Degree Days:	<input type="text" value="5754"/>	Base 65 F	<input type="text" value="2013"/>	Base 55 F
Fuel Type:	<input type="text" value="NG"/>		<input type="text" value="Electric"/>	
System Efficiency:	<input type="text" value="80"/>	% Seasonal Eff	<input type="text" value="10"/>	SEER/EER
Fuel Cost:	<input type="text" value="1.23"/>	\$ / therm	<input type="text" value="0.16"/>	\$ / kWh
Demand Charge:			<input type="text" value="10.00"/>	\$ / kW / Month

Annual Ventilation Load	Heating Season	Cooling Season
No Energy Recovery (BTUs)	119,812,090	41,915,491
With RenewAir ERV (BTUs)	31,151,143	10,898,028
RenewAir Savings (BTUs)	88,660,946	31,017,463

Annual Energy Cost/Savings	Heating Season	Cooling Season
No Energy Recovery	\$1,842.11	\$670.65
With RenewAir ERV	\$478.95	\$174.37
RenewAir Savings	\$1,363.16	\$496.28
Total Energy Savings With RenewAir		\$1,859.44


Simple Payback

Installed ERV Cost:	\$ 12000.00
Utility and Government Rebates:	\$ 6000.00
Conventional Ventilation System Installed Cost:	\$ 1205.00
Conventional AC System Installed Cost:	\$ 0.00

Net RenewAir Cost Over Conventional Alternatives:	\$4,795.00
Annual Energy Savings:	\$1,859.44
Annual Demand Savings:	\$0.00
Total Annual Savings:	\$1,859.44
Simple Payback:	2.6 Years

Hurdles

- Occupant Participation
- Complex Envelope
 - Antique windows
 - Variation in efficiency
- Infiltration/ventilation



Ideal Conditions

- Blower Door Test/infiltration rates
 - Within + into building
- Air quality
- Air flow analysis
- Q_{in}

Acknowledgements



- Dave Ford, John Cobb, Jon Goff , Herreshoff
- Chris Bull, Michelle Flagg
- Kevin from Renewaire
- Kate Goldstein, '08
- Kert Teichurt

Thank You!



